



**GOVERNMENT OF TELANGANA
(Medical & Health Department)**

From:
Dr.G.Gayathri Devi.,MBBS.,DPH..
Dist.Medl.& Health Officer,
Sangareddy. District.

To
District Educational Officer,
Sangareddy District ,

Rc.No. 4597/D&O/DM&HO/SRD/2019., Dated:24-05-2025.

Sir,

Sub:- D&O ACT–SANITARY CERTIFICATE–Renewal of Sanitary Certificate in respect of M/s. Surya the Global School, Survey 123/1 & 123, Precon villas, Ameenpur, Patancheru (M), Sangareddy District.–Reg.

Ref:- Application of the Principal, M/s. Surya the Global School, Ameenpur, Patancheru (M), Sangareddy District, Dated : 12-05-2025.

& & &

Vide reference cited, the Principal, M/s. Surya the Global School, Ameenpur, Patancheru (M), Sangareddy District has applied for Sanitary Certificate, accordingly the premises of above school, has been inspected by the authorities of District Medical & Health Officer Office Sangareddy.

Certified that the sanitary arrangements and amenities provided in the premises of the M/s. Surya the Global School, Ameenpur, Patancheru (M) Sangareddy District are satisfactory at the time of inspection.

1. That the accommodation provided for each of the several classes is sufficient for the maximum number of pupils taught therein.
2. That the class rooms are properly ventilated and lighted.
4. That the Toilets arrangements are sufficiat for 450 (Four Hundredd Fiftey only) students
5. That in all other aspects the sanitation is good.
6. The fire Safety arrangements are taken in the School.
7. Follow the Covid -19 guidelines issued by TS government time to time.

The inspecting authorities are visiting to premises as and when complaints received if any from the students / public.

This certificate is valid for Academic Year 2025-2026.

This certificate is liable to be cancelled at any time without any prior notice, if the sanitary arrangements are found un-satisfactory.

Yours faithfully,

**Dist.Medl.& Health Officer,
Sangareddy District.**

Copy to the Principal, M/s. Surya the Global School, Ameenpur, Patancheru (M), Sangareddy District

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
Directorate of I.P.M,P.H.Labs, Food (II) Administration, Narayanaguda.

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From: Surya The Global School, Sy.No:123 & 124, Ameenpur (Vill)

2. Collected by: K.Mahesh

3. Collected on : 26-04-2025

4. Received on: 26/04/2025

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total Coliform Bacteria (MPN Index) per 100ml	Faecal Coliform Bacteria per 100ml	Esch. Coli per 100ml	Result
6590	Borewell water	Direct Borewell water	...	≥1609	Absent	Present	Unsatisfactory, Presence of E.Coli indicates Faecal contamination
6592	R.O water	Direct from R.O plant	Nil	Satisfactory
6593	R.O water (TPC)	Direct from R.O plant	Total Aerobic Bacterial Plate Count for 24 hrs at 37 ^o c = 2 CFU / ml				Satisfactory

Signature 07/05/25
Dy. Chief Water Analyst

Dy. Chief Water Analyst
Dept. of Water & Waste Water
Institute of Preventive Medicine
Public Health Labs & Food (II) Administration
Narayanaguda, Hyderabad-28

GOVERNMENT OF TELANGANA

DEPARTMENT OF WATER AND WASTE WATER EXAMINATION

Directorate of I.P.M.P.H.Labs, Food (H) Administration, Narayanaguda, Hyderabad – 29.


REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample From	Surya The Global School	Collected by	K.Mahesh
Address	Sy.No:123 & 124, Ameenpur (Vill)	Collected on	26-04-2025
District	Received on	26-04-2025
State	TS	Sample volume	2 ltr
Source profile	Metro water	Sample ID	6591 / 6594

S.No	Parameter	Source / Sample ID		Requirement (Acceptable)	Permissible limit in the absence of alternative source
		Ditrect Borewell water / 6591	Ditrect from R.O plant / 6594		
Physical parameters					
1	colour(Hazen),max	<5	<5	5	15
2	Turbidity (NTU),max	1.12	0.38	1	5
3	Odour	Un-Objectionable	UnObjectionable	UnObjectionable	UnObjectionable
4	Taste	Agreeable	Agreeable	Agreeable	Agreeable
5	p ^H	7.7	7.2	6.5 - 8.5	No relaxation
6	Electrical Conductivity at 25°C (Micro Mhos/cm)	1320	101
7	TDS(mg/L),max	858	65.7	500	2000
Chemical parameters (mg/L)					
1	Alkalinity(as CaCO ₃),phenolphthalein ,max	Nil	Nil
2	Total alkalinity (as CaCO ₃),max	308	16	200	600
3	Total hardness (as CaCO ₃),max	340	11	200	600
4	Calcium hardness (as CaCO ₃),max	260	5
5	Magnesium hardness (as CaCO ₃),max	80	6
6	Calcium (as Ca),max	104	2.0	75	200
7	Magnesium (as Mg),max	19.5	1.46	30	100
8	Ammonical Nitrogen,max	Nil	Nil
9	Nitrite(as N),max	Traces	Nil
10	Nitrate(as N),max	1.8	Nil	45	No relaxation
11	Sulphate (as SO ₄),max	5	Nil	200	400
12	Chloride(as Cl),max	144	16	250	1000
13	Fluoride(as F),max	1.62	0.08	1.0	1.5
14	Iron (as Fe),max	Nil	Nil	0.3	No relaxation

Remarks: The sample with Lab Ref No: 6591 is physico chemically unsatisfactory as total hardness is above desirable limit & fluoride is above permissible limit.

The sample with Lab Ref No: 6594 is physico chemically satisfactory .


 Dy. Chief Water Analyst
 Department of Water & Waste Water
 Dy. Chief Water Analytist
 Public Health Labs & Food (H) Administration
 Narayanaguda, Hyderabad-29.